



ADDENDUM NO. 1, DATED 5/18/2010

RE: Invitation To Bid To Furnish And Deliver 205 Kw Generator W/600 Amp ATS, Remote Annunciator, Etc. For The Southeastern Physical Plant Department

BID OPENING DATE/TIME: June 3, 2010, 2:00 P.M., Central Time

Dear Bidder,

The following deletions/additions are issued and shall become a part of the solicitation document:

TO AMEND:

Reference Page 2 / Section 2.0 / Item 2.1 / Paragraph 1:

AMENDED TO:

Gaseous Fueled Engine-Generator Set: Engine-generator set rated for DUAL FUEL to supply at least 205 KW on natural gas and 165 kW on Liquid Propane, at a continuous standby rating, based upon an altitude of 3000 feet, and ambient temperatures up to 104 degrees F., 120/208 volt, three phase, 60 hertz, 1800 rpm.

The generator set shall be complete with the required vaporizer mounted on the engine.

Bidder should reference the addendum in the appropriate blank on the Bid Response Form to acknowledge receipt of the addendum. In the event the bidder has already returned a bid response, then the bidder should return by fax or mail this addendum to acknowledge receipt thereof.

Sincerely,

Ed Gautier

Ed Gautier
Director of Purchasing

cc: Chris Asprion
File

Addendum Acknowledged By:

Name of Business: _____

Signature: _____ Date: _____

Print Name: _____ Title: _____